

Note di Applicazione – Cod. TM11A

Italiano:

Quando si collega il TM11A01KNX ad un attuatore per fan coil è assolutamente necessario che l'attuatore disponga di un interblocco logico tra i relè che pilotano le velocità così come tra i relè che attivano la valvola (quando il sistema è a 4 tubi e necessita pertanto di 2 valvole).

Per ragioni di sicurezza é quindi assolutamente sconsigliabile utilizzare attuatori che non abbiano la funzione di interblocco demandando quindi al termostato il controllo del fatto che sia attivata solo una velocità o una valvola alla volta.

La funzione di interblocco è presente sugli attuatori con cod. IO44B01 / IO44B02 – IO88B02 – IO88E01.

Application Note – Code TM11A

English:

When connecting the TM11A01KNX to a fan coil actuator is absolutely necessary for the actuator to have a interlock function between the relays that drive the speed and also between the relays that activate the valve (on a 4 pipe system 2 different valves are required).

For security reasons, is absolutely not recommended to use actuators that do not have the interlock function and let the thermostat to control that is activated only one speed or one valve at a time.

The interlock function is present on the actuators with cod. IO44B01 / IO44B02 - IO88B02 - IO88E01.